

# NFRC Product Certification Authorization Report



**Manufacturer:** Dealers Supply & Lumber Co., LLC

**Product Series:** VictorBilt Palmetto Double Hung window

**Simulation Lab:** SQTI

**Initial Cert. Date:** 07/25/2012

**Street:** PO Box 5025

**Product Type:** VSDH

**Sim. Report #:** 310-2659E0A0

**Re-Certification Date:**

**City/State/Zip:** Greenville, SC 29606

**Air Leakage:**

**Sim. Report Date:** 07/20/2012

**Revised Date:** 07/20/2012

**Print Date:** 07/25/2012

**Test Date:** 07/20/2012

**Expiration Date:** 07/20/2016

CPD Number: DSL-A-1

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00001-00001	No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: AIR (100)	N		CL	0.42	0.54	0.58	48
	00001-00002	No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.42	0.48	0.51	48
	00002-00001	No Grid, All Grid	OT/OT	2	0.018(2)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.20	0.45	66
	00002-00002	No Grid, All Grid	OT/OT	2	0.018(2)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.18	0.40	66
	00003-00001	No Grid, All Grid	OT/OT	2	0.018(3)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.27	0.45	66
	00003-00002	No Grid, All Grid	OT/OT	2	0.018(3)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.24	0.40	66
	00004-00001	No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.20	0.46	66
	00004-00002	No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.18	0.40	66
	00005-00001	No Grid, All Grid	OT/OT	2	0.022(3)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.28	0.46	66
	00005-00002	No Grid, All Grid	OT/OT	2	0.022(3)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.25	0.40	66
	00006-00001	No Grid, All Grid	OT/OT	2	0.022(2),0.149(4)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.24	0.18	0.41	49
	00006-00002	No Grid, All Grid	OT/OT	2	0.022(2),0.149(4)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.24	0.16	0.36	49
	00007-00001	No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.40	0.54	0.58	50
	00007-00002	No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.40	0.49	0.51	50
	00008-00001	No Grid, All Grid	OT/OT	2	0.018(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.20	0.45	70
	00008-00002	No Grid, All Grid	OT/OT	2	0.018(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.18	0.40	70
	00009-00001	No Grid, All Grid	OT/OT	2	0.018(3)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.27	0.45	70
	00009-00002	No Grid, All Grid	OT/OT	2	0.018(3)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.24	0.40	70
	00010-00001	No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.20	0.46	70
	00010-00002	No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.18	0.40	70
	00011-00001	No Grid, All Grid	OT/OT	2	0.022(3)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.28	0.46	70
	00011-00002	No Grid, All Grid	OT/OT	2	0.022(3)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.25	0.40	70
	00012-00001	No Grid, All Grid	OT/OT	2	0.022(2),0.149(4)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.22	0.18	0.41	54
	00012-00002	No Grid, All Grid	OT/OT	2	0.022(2),0.149(4)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.22	0.16	0.36	54

# NFRC Product Certification Authorization Report



**Manufacturer:** Dealers Supply & Lumber Co., LLC     
**Product Series:** VictorBilt Palmetto Double Hung window     
**Simulation Lab:** SQTI     
**Initial Cert. Date:** 07/25/2012  
**Street:** PO Box 5025     
**Product Type:** VSDH     
**Sim. Report #:** 310-2659E0A0     
**Re-Certification Date:**  
**City/State/Zip:** Greenville, SC 29606     
**Air Leakage:**     
**Sim. Report Date:** 07/20/2012     
**Revised Date:** 07/20/2012  
**Print Date:** 07/25/2012     
**Test Date:** 07/20/2012     
**Expiration Date:** 07/20/2016

CPD Number: DSL-A-1													IA: American Architectural Manufacturers Association			
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00013-00001	No Grid	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.23	0.17	0.33	70	
	00014-00001	Grid 1	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.24	0.16	0.29	70	
	00015-00001	No Grid	OT/OT	3	0.018(2),0.018(5)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	N		CL	0.20	0.17	0.33	73	
	00016-00001	Grid 1	OT/OT	3	0.018(2),0.018(5)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	G	0.75	CL	0.20	0.15	0.29	73	
	00017-00001	No Grid	OT/OT	3	0.022(2)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	N		CL	0.24	0.18	0.41	69	
	00018-00001	Grid 1	OT/OT	3	0.022(2)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	G	0.75	CL	0.25	0.17	0.37	69	
	00019-00001	No Grid	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	N		CL	0.20	0.17	0.33	73	
	00020-00001	Grid 1	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: ARG/AIR (90/10),Fill 2: ARG/AIR (90/10)	G	0.75	CL	0.20	0.15	0.29	73	
	00021-00001	No Grid	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: KRY/AIR (90/10),Fill 2: KRY/AIR (90/10)	N		CL	0.16	0.17	0.33	76	
	00022-00001	Grid 1	OT/OT	3	0.022(2),0.022(5)	0.313,0.313	P1-S	Fill 1: KRY/AIR (90/10),Fill 2: KRY/AIR (90/10)	G	0.75	CL	0.16	0.15	0.29	75	
	00023-00001	DP, No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: AIR (100)	N		CL	0.41	0.54	0.58	46	
	00023-00002	DP, No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.41	0.48	0.51	46	
	00024-00001	DP, No Grid, All Grid	OT/OT	2	0.037(2)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.26	0.49	57	
	00024-00002	DP, No Grid, All Grid	OT/OT	2	0.037(2)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.24	0.44	57	
	00025-00001	DP, No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.40	0.54	0.58	47	

# NFRC Product Certification Authorization Report



**Manufacturer:** Dealers Supply & Lumber Co., LLC     
 **Product Series:** VictorBilt Palmetto Double Hung window     
 **Simulation Lab:** SQTI     
 **Initial Cert. Date:** 07/25/2012  
**Street:** PO Box 5025     
**Product Type:** VSDH     
**Sim. Report #:** 310-2659E0A0     
**Re-Certification Date:**  
**City/State/Zip:** Greenville, SC 29606     
**Air Leakage:**     
**Sim. Report Date:** 07/20/2012     
**Revised Date:** 07/20/2012  
**Print Date:** 07/25/2012     
**Test Date:** 07/20/2012     
**Expiration Date:** 07/20/2016

CPD Number: DSL-A-1			IA: American Architectural Manufacturers Association												
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00025-00002	DP, No Grid, All Grid	OT/OT	2		0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.40	0.49	0.51	47
	00026-00001	DP, No Grid, All Grid	OT/OT	2	0.037(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.26	0.49	61
	00026-00002	DP, No Grid, All Grid	OT/OT	2	0.037(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.24	0.44	61
	00027-00001	DP, No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: AIR (100)	N		CL	0.29	0.20	0.46	58
	00027-00002	DP, No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: AIR (100)	G	0.75	CL	0.29	0.18	0.40	58
	00028-00001	DP, No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.26	0.20	0.46	62
	00028-00002	DP, No Grid, All Grid	OT/OT	2	0.022(2)	0.625	P1-S	Fill 1: ARG/AIR (90/10)	G	0.75	CL	0.26	0.18	0.40	62

---

**Baseline Information**

<b>Test Lab</b>	<b>Test Date</b>	<b>Test Size</b>	<b>Tested U-Value</b>	<b>Standard U-Value</b>	<b>Test Report Number</b>
<b>TQTI</b>	<b>07/20/2012</b>	1194mm x 1499mm	0.240	0.240	310-2783-E0A0

**Comments:**

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA  
Signature: \_\_\_\_\_